

TC716 draft comments:

## 716.1 Scope

This part of IEC 60364 specifies requirements in electrical installations for the distribution of ELV DC range power using balanced, information technology cables and accessories primarily designed for data transmission, as specified in terms of a Category within the reference implementations of **ISO/IEC 11801-1** using power feeding equipment in accordance with IEC62368-3.

Requirements are included for the design, erection, and verification of telecommunications infrastructure for the purpose of both telecommunications and distribution of ELV DC power feeding. In addition requirements are included for use of existing telecommunications infrastructure for distribution of ELV DC power.

The power delivery systems include, but are not restricted to, the Power over Ethernet systems specified by IEEE 802.3.

**Comment:** The reference to 11801-1 should be dated. The entire proper reference is: ISO/IEC 11801-1:2017 as modified by Cor 1:2018. IEEE 802.3 notes that PoE systems specified in IEEE 802.3 include the PoDL systems defined in Clause 104 that operate on a single pair. 11801-1 at present only covers the 2-pair and 4-pair systems compatible with 802.3 Clause 33 and Clause 145. Additionally, 11801-1 may never cover single pair.

**CLOSED**

---

### 716.433.1.101 Protection against thermal effects including overcurrent

The protection against thermal effects and overcurrent shall be achieved by at least one of the three following principle measures:

- use of a protective device to disconnect any overcurrent in the circuit conductors
- designing the circuit so as to prevent an overcurrent to arise
- limitation of overcurrent by the characteristics of supply

The measure used to protect against thermal effects and overcurrent may reset automatically.

### 716.433.1.101a Protection against overload

Overload protection shall be provided by limitation of the power supply for all parallel sources of the power supply devices. The disconnection in case of overload shall be within 1 s. The circuit shall not reset automatically.

Comment: The sentence “The circuit shall not reset automatically.” seems to disallow products that have multiple levels of current limit with different protections at each limit. The 802.3 PoE specification requires a (self-resetting) current foldback when the maximum rated supply current is reached. Outside the scope of the IEEE 802.3 specification, products usually have a fuse to meet the stated overcurrent protection required. The text should be clarified so that it is more explicit that multiple protection levels are allowed as long as one of the protections does not reset automatically.

~~The sentence “The circuit shall not reset automatically.” disallows products from having multiple levels of current limit. The text seems to attempt to require a fuse that does not self reset, but the text can also be interpreted to apply to devices that also have electronic limits at lower levels to prevent the need for manual intervention. Outside the scope of the IEEE 802.3 specification, products usually have a fuse to meet requirements such as these. IEEE 802.3 PoE compliant devices are required to also have lower electronic limits (foldback).~~

Normal Power Sourcing Equipment (PSE) operation is described in the following:

PSEs have current limits  $I_{lim}$  and  $I_{cut}$ .  $I_{cut}$  is a ‘PSE may shut off the port’ current limit and  $I_{lim}$  is a ‘PSE shall shut off the port’ current limit.  $I_{cut}$  is tripped when a Power Device (PD) draws more power than it advertised during classification for longer than 75ms max.  $I_{lim}$  is tripped when the PD exceeds this power by a given percentage that varies according to the Type (this percentage decreases with increase power output/draw ~14% max). The  $I_{lim}$  min timing is Type dependent but is 75ms max for any Type. Most PSEs will choose the lower  $T_{lim}$  numbers (6 or 10ms) as thermal dissipation can be problematic at these operating points. In either of these cases ( $I_{cut}$  or  $I_{lim}$ ), the PSE moves back to detection after shutting off the port. If the PD presents valid detection and classification signatures and does not fail inrush, power will be applied again automatically. This is by design. Customers do not want to manually intervene in a misbehaving PD (misbehaving being a PD that is poorly designed such that it trips the current limits occasionally but is not damaged or a hazard). The PSE has an error delay timing spec that requires a 750ms delay before subsequent powering attempts. These timing requirements limit

the duty cycle of any error event to less than 10% to ensure that there is no heating due to successive fault events.

IEEE 802.3 requests that the language of this section be modified to allow the above described behavior as hundreds of millions of ports are already in existence that will not conform and likely cannot be upgraded to comply.

One solution would be to clarify it is just the overload protection that cannot reset automatically. This can be accomplished by making a new section just for overload and adding a sentence to the overcurrent section:

After the list of principle measures in 433.1.101 add:

The measure used to protect against thermal effects and overcurrent may reset automatically.

716.433.1.101a Protection against overload

---

716.521 Types of wiring system  
716.521.101

Information technology cables used for the distribution of DC power shall comply with Category 5, Category 6, Category 6A, Category 7, Category 7A, Category 8.1 or Category 8.2

Comment: change “Information technology cables used for the distribution of DC power...” to “Information technology cables and components used for the distribution of DC power...”

CLOSED

---

716.523 Current carrying capacities  
716.523.1.101

The maximum operating temperature for **cables** complying with ISO/IEC 11801-1 requirements for Category 5, Category 6, Category 6A, Category 7, Category 7A, Category 8.1 or Category 8.2 shall not exceed 60°C.

Comment: Change to: The maximum operating temperature for Category 5, Category 6, Category 6A, Category 7, Category 7A, Category 8.1 or Category 8.2 cables and components shall not exceed ISO/IEC 11801-1 requirements.

**CLOSED**

---

## NEC Public Comments

### 250.119 Identification of Equipment Grounding Conductors.

Unless required elsewhere in this Code, equipment grounding conductors shall be permitted to be bare, covered, or insulated. **Individually covered or insulated equipment grounding conductors shall have a continuous outer finish that is either green or green with one or more yellow stripes except as permitted in this section.** Conductors with insulation or individual covering that is green, green with one or more yellow stripes, or otherwise identified as permitted by this section shall not be used for ungrounded or grounded circuit conductors.

Exception No. 1: Power-limited Class 2 or Class 3 cables, power-limited fire alarm cables, or **communications cables containing only circuits operating at less than 50 volts where connected to equipment not required to be grounded in accordance with 250.112(I) shall be permitted to use a conductor with green insulation or green with one or more yellow stripes for other than equipment grounding purposes.**

[for reference: 250.112 Specific Equipment Fastened in Place (Fixed) or Connected by Permanent Wiring Methods. Except as permitted in 250.112(F) and (I), exposed, normally non-current-carrying metal parts of equipment described in 250.112(A) through (K), and normally non-current-carrying metal parts of equipment and enclosures described in 250.112(L) and (M), shall be connected to an equipment grounding conductor, regardless of voltage.

(I) Remote-Control, Signaling, and Fire Alarm Circuits.

Equipment supplied by Class 1 circuits shall be grounded unless operating at less than 50 volts. Equipment supplied by Class 1 power-limited circuits, by Class 2 and Class 3 remote-control and signaling circuits, and by fire alarm circuits shall be grounded where system grounding is required by Part II (**System Grounding**) or Part VIII (**Direct-Current Systems**) of this article.]

### PC #1:

This comment is filed on behalf of the IEEE 802.3 Working Group. For reference, this comment is labeled IEEE802.3#1.

The addition of PoE to 725.144 in the 2017 NEC has the unintended consequence that green conductors in a Category cable must be equipment ground. 250.119 Exemption No. 1 allows green conductors to not be equipment ground, but only for circuits of less than 50V. Some IEEE compliant standardized PoE systems have a minimum port voltage of 50V and all of them limit maximum port voltage to 57V. Therefore, IEEE compliant PoE does not qualify for the exemption, making hundreds of millions of PoE installations violate the Code. This exemption was added from the inception of this text, specifically for Category cabling. If these Ethernet ports were forced to follow Code, they would not be functioning today as the requirement to have the green conductors be equipment ground would halt communication. An exemption in practice exists where it does not exist in text – hundreds of millions of these ports have been installed for almost 20 years operating at or above 50V with zero record of loss. IEEE 802.3 requests to fix the exemption by changing 50V to 60V. When PoE was developed, 60V was chosen as the maximum allowable voltage based on the Safety Extra Low Voltage (SELV) section of IEC/UL 60950.

### PC#2:

This comment is filed on behalf of the IEEE 802.3 Working Group. This is a companion comment to a previous comment labeled IEEE802.3#1. If IEEE802.3#1 is accepted, this comment is withdrawn.

The addition of PoE to 725.144 in the 2017 NEC has the unintended consequence that green conductors in a Category cable must be equipment ground. 250.119 Exception No. 1 intends to allow Category cable to have green covered or insulated individual conductors that are not equipment ground but limits the exemption to 50V, therefore excluding PoE systems which operate up to 60V (based on the SELV section of IEC/UL 60950). An alternate solution to raising the voltage in Exception No. 1 to 60V is to add a new exception.

*Exception No. 1a: Systems using Category cabling as described in ANSI/TIA-568.2-D-2018 that have 2.25kV DC or 1.5kV AC isolation from earth ground to the twisted pair signal conductors shall be permitted to use a conductor with green insulation or green with one or more stripes for other than equipment grounding purposes.*

CLOSED

---

725.144

## Nominal Current

PC#3:

This comment is filed on behalf of the IEEE 802.3 Working Group.

IEEE 802.3 believes that using different terms (“nominal current” in 725.121(C) and 725.144 and “rated current” in 840.160) leads to confusion. We recommend that 725.121(C) and 725.144 use “rated current” along with an informational note to clarify the meaning of “rated current” as the highest output current per conductor that the power source is designed to deliver excluding fault and transient conditions, and making allowance for unbalance found in these systems will provide more usable code. IEEE 802.3 supports the work of the Correlating Committee commissioned PoE TG that developed the following informational note (as covered in PC755 along with companions PC763, PC765, PC766, PC769, and PC772 filed by Ernest Gallo on behalf of the TG):

Informational Note No. 6: Rated Current for power sources covered under 725.144 is the highest output current per conductor the power source is designed to deliver to an operational load at normal operating conditions, as declared by the manufacturer. In the design of these systems, the actual current in a given conductor might vary from the rated current per conductor by as much as 20%. An increase in current in one conductor is offset by a corresponding decrease in current in one or more conductors of the same cable.