


# **Power Backoff Consideration in Clause 55.7.3.3 May Lead to Wrong Result on AxTalk**

**HARSHANG PANDYA and XING ZHU**

**Agilent Technologies**


**Feb 2006**

## Near End



- Length of cables:  $L_1 < L_d < L_2$
- Insertion loss of cables:  $IL_1 < IL_d < IL_2$
- Received Power at near end:  $P1, P2$  (=  $T_{xr\_power} - back\_off - insertion\ loss$ )

Item	Case 1: disturber cable --> Victim Cable #1	Case 2 disturber cable --> Victim Cable #2	Comment
Measured Insertion Loss	$IL_{-1}, IL_{-d}$ (where $IL_{-1} < IL_{-d}$ )	$IL_{-2}, IL_{-d}$ (where $IL_{-d} < IL_{-2}$ )	
Derived cable length	$L_{-1}, L_{-d}$ (where $L_{-1} < L_{-d}$ )	$L_{-2}, L_{-d}$ (where $L_{-d} < L_{-2}$ )	
Power backoff for disturber and victim cables	$PBO_{-1}, PBO_{-d}$ (where $PBO_{-1} > PBO_{-d}$ )	$PBO_{-2}, PBO_{-d}$ (where $PBO_{-d} > PBO_{-2}$ )	
Td Power	$Pt1 - PBO_{-d}$	$Pt1 - PBO_{-d}$	same
Received power at near end	$P1 = P_{-T1r} - IL_{-1} - PBO_{-1}$	$P2 = P_{-T2r} - IL_{-2} - PBO_{-2}$	$P1 = P2$
IL_bof	$IL_{-bof1} = PBO_{-d} - PBO_{-1}$	$IL_{-bof2} = PBO_{-d} - PBO_{-2}$	$IL_{-bof1} < IL_{-bof2}$
Actual ANEXT at one victim pair from each pair i of disturber	$AN_{-i}$	$AN_{-i}$	suppose $AN_{-i}=AN_{-i}$
Actual PSANEXT	$PSANEXT_{-1} = AN_{-1}+AN_{-2}+AN_{-3}+AN_{-4}$	$PSANEXT_{-2} = AN_{-1}+AN_{-2}+AN_{-3}+AN_{-4}$	$PSANEXT_{-1}$ equal to $PSANEXT_{-2}$
Received power to PSANEXT noise ratio	$SNR1 = P1 / PSANEXT_{-1}$	$SNR2 = P2 / PSANEXT_{-2}$	$SNR1$ equal to $SNR2$
Computed PSANEXT with power backoff compensation: Pp159, Clause 55.7.3.3, Formula (55-36)	$PSANEXT_{-1}' = (AN_{-1}+IL_{-bof1})+(AN_{-2}+IL_{-bof1}) + (AN_{-3}+IL_{-bof1})+(AN_{-4}+IL_{-bof1})$	$PSANEXT_{-2}' = (AN_{-1}+IL_{-bof2})+(AN_{-2}+IL_{-bof2}) + (AN_{-3}+IL_{-bof2})+(AN_{-4}+IL_{-bof2})$	$PSANEXT_{-1}'$ not equal to $PSANEXT_{-2}$
Received power to Computed PSANEXT noise ratio	$SNR1' = P1 / PSANEXT_{-1}'$	$SNR2' = P2 / PSANEXT_{-2}'$	$SNR1'$ not equal to $SNR2'$



	Case 1	Case 2	comments
Measured Insertion Loss (dB)	27.1	23.1	
Derived disturbed cable length(meter)	75.1	64.0	
Power back-off	0.0	4.0	
Txr power at far end	P_T1r	P_T1r-4.0	
Received Power at near end (= tx power - back-off - insertion loss)	P_T1r-27.1	P_T1r-27.1	same for both setup (P1=P2)
Actual PSANEXT power (raw magnitude)	Paxt	Paxt	assume same for both setup
Received power to Actual PSANEXT noise ratio	$(P\_T1r-27.1)/Paxt$	$(P\_T1r-27.1)/Paxt$	<i>same for both setup</i>
IL_bof	0	-4	assume min_PBO_disturbinglink=0
Computed PSANEXT' based on IL_bof	-Paxt	-(Paxt-4)	<i>different</i>
Received power to Computed PSANEXT' noise ratio	$(P\_T1r-27.1)/Paxt$	$(P\_T1r-27.1)/(Paxt-4)$	<i>different</i>

Conclusion: power back-off considerations will cause different measurement results for the channels experiencing same noise and having same received power

## **Conclusion:**

**The power backoff compensation proposed in Clause 55.7.3 may lead to difference between the actual and computed PSANEXT.**