UPSTREAM RF POWER AMPLIFIER TURN ON TIME AND TURN OFF TIME PROPOSED TREATMENT



Author: Mark Laubach





- Comment #3481 has a proposed reject due file not included
- This presentation and draft text file are put forth as a response for consideration of changing to an accept status.

PMD TURN ON AND TURN OFF TIMES



EPON has laser turn on and turn off times

- See 75.7.14 -> 60.7.13.1.1
- Time on and off is reported by the manufacturer
 - Reported via laserOffTimeCapability and laserOnTimeCapability, see 77.3.3.1
 - Maximum 512 ns.
- These times are included as part of MPCP burst overhead calculations
 - Different ONUs will collide and interfere
- Power saving is included
- Signaled via PMD_SIGNAL.request() from PCS Data Detector
 - ONU only, OLT is always "on"

EPoC has RF power amplifier (PA) turn on and turn off requirements

- Need primarily for power saving, we've made it a requirement
 - Secondary effect is to not create CLT receiver cumulative SNR issues from all CNU PAs being on.
- PAs of different CNUs do not collide before or after the burst
 - PA turn on and turn off times do not need to be included in MPCP burst overhead
- Should also be signaled via PMD_SIGNAL.request() from PCS Data Detector
 - CNU only, CLT is always "on"



PA turn on includes turn on time to stabilization

- E.g. power supply settles, meets fidelity requirements
- Vendor knows the time characterization of their selected PAs for this
- Expect $\leq \sim 20 \ \mu s$ typical turn on time, maximum of 100 μs

PA turn off is a non-issue

- Assertion: both turn on and turn off times are not needed for burst overhead for scheduling
 - They are a figure of merit for power savings

What about grant lead times?

Should not be an issue due to PMA pipeline, see next slide



• When the CNU data detector output process begins sending a burst:


- PMD_SIGNAL.request() state transitions arrive "instantly" at the PMD
- Actual burst data has to transit the PMA processes:
 - Symbol Mapper: 8 or 16 times 20 µs delay (*RBsize*)
 - IDFT: 10 µs to 40 µs delay, vendor dependent, but has to meet PMA delay variation requirements
- Time through the PMA (TPMA) will be the sum of these two pipeline delays
 - Fixed for any upstream profile configuration
 - Ends up being included in EPON RTT

Grant lead time?


No impact due to larger TPMA

TPMA

- Likely minimum: 8 * 20 + 10 = 170 μs
- Likely maximum: 16 * 20 + 40 = 360 µs



PMD BURST TIMING



PMD burst timing diagram would look like the above

- We've already defined the granted upstream burst in 101.3.2.5.3
- Vendors will know their TPMA and Ron times and internal timing for the advance turn on of their PAs
 - The requirement in the specification is that the upstream burst meets fidelity requirements, which means PA turn on to stabilization
- This diagram and draft text will satisfying those looking at the draft for RF amplifier impact and power savings



Works ok from PCS CNU Data Detector Output

- PCS data burst
- PCS data burst + PHY Link message in same RB Frames
- Need to add to PHY Link transmission path just before equivalent symbol mapper
 - Same time delay as TPMA: 8 or 16 * 20 μs + IDFT time.
 - Need to add equivalent text similar to PCS text to PHY Link
- RF PA text needs to state OR of signals from PCS and from PHY Link: either one "ON" signals on RF PA, both "OFF" signals off.

DRAFT TEXT



- Review comment # 3481 for consideration of overcoming rejection
- Review laubach_3bn_03_0515.pdf (and fm) for consideration as replacing laubach_3bn_1X_0515.pdf in the comment.

PROPOSAL



Adopt laubach_3bn_03_0315.pdf as part of resolution for comment #



Thank you