

IEEE 802.3 Ethernet Working Group Liaison Communication

Source: IEEE 802.3 Working Group¹

To: Ray Emplit Chair, TIA TR-42 Engineering Committee
remplit@harger.com

CC: Konstantinos Karachalios Secretary, IEEE-SA Standards Board
Secretary, IEEE-SA Board of Governors
sasecretary@ieee.org

Paul Nikolich Chair, IEEE 802 LMSC
p.nikolich@ieee.org

Adam Healey Vice-chair, IEEE 802.3 Ethernet Working Group
adam.healey@broadcom.com

Pete Anslow Secretary, IEEE 802.3 Ethernet Working Group
panslow@ciena.com

Valerie Maguire TIA Incoming Liaison to IEEE 802.3 Working Group
valerie_maguire@siemon.com

Chris DiMinico IEEE 802.3 Working Group Incoming Liaison to TIA
cdiminico@ieee.org

Ed Larson Chair, IEEE-SA SCC18
ed.larsen@schneider-electric.com

From: David Law Chair, IEEE 802.3 Ethernet Working Group
dlaw@hpe.com

Subject: Power delivery over communications cabling

Approval: Agreed to at IEEE 802.3 Plenary meeting, San Diego, CA, USA, 28th July 2016

Dear Mr. Emplit,

We are concerned that the 2017 National Electrical Code® revisions in Table 725.144 have effectively created a “new” class of communication cables for operating temperatures greater than 60°C with designated ampacity limits for powering, without consideration for the transmission characteristics related to the application usage.

At this time, no known IEEE 802.3 communications and/or power delivery have been specified for operation on data center or enterprise Ethernet based communications circuits at 90°C conductor temperature. IEEE 802.3 references TIA and ISO/IEC cabling functionally specified over the temperature range from -10°C to +60°C. Cabling transmission characteristics beyond 60°C are not specified, therefore IEEE 802.3 operation may not be supported. This is independent of whether the cabling itself may survive exposure to such temperatures.

Table 725.144 in the 2017 National Electrical Code revision may apply to communication cables carrying power and data with the implication of applicability to balanced twisted pair

¹ This document solely represents the views of the IEEE 802.3 Working Group, and does not necessarily represent a position of the IEEE, the IEEE Standards Association, or IEEE 802.

structured cabling. IEEE 802.3 would appreciate TIA TR-42's assistance in addressing the implications of the 2017 National Electrical Code revision.

Sincerely,
David Law
Chair, IEEE 802.3 Ethernet Working Group