

IEEE 802.3 Ethernet Working Group Liaison Communication

Source: IEEE 802.3 Working Group¹

To: Mark Earley Chief Electrical Engineer, NFPA
mwearley@nfpa.org

Konstantinos Karachalios Secretary, IEEE-SA Standards Board
Secretary, IEEE-SA Board of Governors
constantin@ieee.org

Paul Nikolich Chair, IEEE 802 LMSC
p.nikolich@ieee.org

Adam Healey Vice-chair, IEEE 802.3 Ethernet Working Group
adam.healey@broadcom.com

CC: Pete Anslow Secretary, IEEE 802.3 Ethernet Working Group
panslow@ciena.com

Chad Jones Chair, IEEE P802.3bt Task Force
cmjones@cisco.com

Ed Larsen Chair, IEEE SCC18
ed.larsen@schneider-electric.com

Bill McCoy IEEE External Representative to NFPA NEC CMP 16
wjmccoy@verizon.net

George Straniero Chair, NFPA Electrical Section
gstraniero@acfmail.com

Kerry M. Bell Chair, NFPA Standards Council
kerry.m.bell@us.ul.com

Presiding Officer 2016 NFPA Technical Meeting
c/o NFPA Standards Council

Dawn Bellis Secretary, NFPA Standards Council
stds_admin@nfpa.org

John Kovacik Secretary, Electrical Section Board
john.r.kovacik@us.ul.com

From: David Law Chair, IEEE 802.3 Ethernet Working Group
dlaw@hpe.com

Subject: Liaison to NFPA

Approval: Agreed to at IEEE 802.3 Interim meeting, Whistler, BC, Canada, 26th May 2016

Dear Mr. Earley,

Experts in the IEEE 802.3 Working Group have reviewed the Second Revision No. 4564-NFPA 70-2015 [Section, 840.160]. We remain concerned about the technical justification for the proposed changes, pursuant to our liaison of July 2015 and comments submitted on the second draft.

¹ This document solely represents the views of the IEEE 802.3 Working Group, and does not necessarily represent a position of the IEEE, the IEEE Standards Association, or IEEE 802.

Additionally, we are now concerned that a power limit of 60 watts or less does not inherently limit the maximum ampacity of communications cables powering circuits, and therefore is not a sufficient criteria to be used as the basis for excluding communications cables powering circuits from complying with 725.144 ampacity tables. For example, this could allow higher than intended ampacities in other systems, which might use lower voltages.

IEEE Std 802.3 Clause 33 DTE Power over MDI, the only standardized application referred to as Power over Ethernet or PoE, provides managed power to communications equipment consistent within SELV and LPS limits at maximum ampacities under 0.5 amps/conductor, and provides for current monitoring and overcurrent shutoffs.

We appreciate the NFPA's consideration of our comments, concerns, and commitment to an open standards process.

Sincerely,

David Law

Chair, IEEE 802.3 Ethernet Working Group